
Na Příkopě building



Na Příkopě 29,
110 00, Prague 1
Czech Republic

front desk contact: +420 221 619 511, +420 777 367 539

web: www.ff.cuni.cz/home

Support for students and applicants with special needs at the faculty is provided by: PhDr. Mgr. David Čáp, contact: +420 221 619 676, david.cap@ff.cuni.cz

Overview of accessibility



Description of the building

The Česká spořitelna building houses the Department of Social Work, the Institute of Asian Studies (Seminar of Mongolian Studies and Tibetan Studies), the Institute of Bohemian Studies, the Institute of Information Studies and Librarianship, and the Department of Romance Studies (Portuguese).

Entrance

The surface of the access walkway consists of a flat tiled pavement. In front of the entrance, there are 2 steps up (height 2x 10 cm). A mobile roll-out ramp is available during opening hours at the Česká spořitelna branch office on the ground floor with an entrance above the stairs. There is no doorbell in front of the entrance.

The stairs are connected by a passage with a section having a longitudinal slope (gradient 6%, length 150 cm). There is a double-panel automatic door at the end of the passage. The width of the passage is sufficient. The entrance leads to a stairwell with an lift, in front of which there is a turnstile with a wide sidegate (width min. 100 cm).

Interior

A lift connects the passage level to the next floor.

On the 2nd and 3rd above-ground floors, where the Department of Social Work, ECES, and the Institute of Bohemian Studies are located, a double-panel door (main panel width 70 cm, secondary panel width 73 cm) leads from the stairwell from the lift to the interior without a doorbell. The manoeuvring space in the interior is insufficient. The doors of the classrooms and offices are single-panel (width 80 cm). On the 3rd above-ground floor, there is a modified toilet stall (see Sanitary facilities).

On the 4th and 5th above-ground floors, housing the remaining institutes, a double-panel door (main panel width 80 cm, secondary panel width 37 cm) with a doorbell (max. height 149 cm) leads from the stairwell from the lift to the interior.

On the 4th above-ground floor, however, the entrance is followed by a vestibule and another double-panel door with a narrowed main panel (width 2x 61 cm). The manoeuvring space in the interior is sufficient. The doors of the classrooms and offices are single-panel (width 80 cm) with a threshold (height up to 3 cm).

Lift

A lift (automatically opening door width 80 cm; cabin width 118 cm, depth 95 cm) connects the 2nd underground floor to the 5th above-ground floor, except for the street level. The manoeuvring space in front of the lift is sufficient. The cabin is equipped with a handle (height 89 cm) and a mirror (bottom edge height 89 cm) on the front wall. The controls at the entrances are at a maximum height of 119 cm. The maximum height of the controls inside the cabin is 112 cm.

Sanitary facilities

The accessible toilet (door width 80 cm; stall width 168 cm, depth 188 cm) is separate and is located on the 3rd above-ground floor. The single-panel door to the toilet is marked and opens mechanically outwards. Access to the toilet bowl from the stall entrance is on the left. There is enough space for a wheelchair next to the toilet bowl (width 86 cm). The toilet bowl is equipped with two pull-down handles.

Parking

A reserved parallel parking space without access to the pavement is located on the opposite side of Na Příkopě Street. The nearest crossing is barrier-free.