



In front of the main entrance to the building, there is a short staircase (3 steps up), which is insufficiently compensated by a steep single ramp (gradient 28%, width 100 cm, length 162 cm) without measures to prevent wheelchairs from rolling down and without a handrail. The upper landing is spacious. The double-panel entrance door (main panel width 99 cm, secondary panel width 100 cm) opens mechanically outwards. There is no doorbell at the entrance. The reception area is behind the entrance on the right (counter height 88 cm).

The locked side entrance leads to the main building at the junction of the left tract. There are 2 steps up in front of the entrance, which is again insufficiently compensated by a single ramp (gradient 20%, width 82 cm, length 200 cm) without measures to prevent wheelchairs from rolling down and without a handrail. The upper landing is spacious. The double-panel entrance door (main panel width 85 cm, secondary panel width 87 cm) with 1 step up and a metal levelling ramp (gradient 20%, width 60 cm, length 76 cm) opens mechanically outwards. There is no doorbell at the entrance.

A separate entrance leads to the left tract. In front of the entrance, there is a single ramp (gradient 12% to 13%, width 147 cm, length 240 cm) with a double-sided handrail (height 90 cm). The upper landing is spacious.

## Interior

From the main entrance, a staircase with an inclined stair platform leads to the 2<sup>nd</sup> floor (load capacity 300 kg; manoeuvring area width 84 cm, depth 108 cm, controls max. height 113 cm). The manoeuvring space for the lower and upper platforms are sufficient.

The Student Affairs Office, the Department of Biblical Studies and Jewish Studies (door width 2x 60 cm), and auditoriums (door width 2x 60 cm) are located on the 2<sup>nd</sup> above-ground floor.

The 2<sup>nd</sup> to 5<sup>th</sup> above-ground floors of the main tract are connected by a passenger lift to the library, chapel, departments, and the dean's office. The top floor, the 6<sup>th</sup> above-ground floor, with classroom H503 is accessible only by stairs.

The 1<sup>st</sup> above-ground floor (lowered compared to the main entrance), which houses the Karolinum Press, is also accessible from the entrance hall via an inclined stair platform (load capacity 300 kg; manoeuvring area width 84 cm, depth 108 cm, controls max. height 113 cm). The manoeuvring spaces of the lower and upper platforms are sufficient.

The third platform with the same parameters compensates for 6 steps up at the southern end of the corridor of the 1<sup>st</sup> above-ground floor. The upper station of the platform is on the landing of the staircase, which is located between the main and left tracts. The spacious stair landing is a transition area to the fourth inclined stair platform of the same dimensions. However, assistance is required to call up the platform when transferring to the landing.

The fourth platform connects the side entrance level of the main tract (see Entrance), where the Department of Religious Studies, the canteen, and a modified toilet are located, with hall H 109 (door width 2x 72 cm) and the 2<sup>nd</sup> above-ground floor of the left tract of the faculty building.

The left tract with its own entrance (see Entrance) has four floors, which is connected by a lift (see Lift). On the 2<sup>nd</sup> to 4<sup>th</sup> above-ground floors, a central corridor leads from the lift, along which classrooms and offices are located (door width min. 80 cm). On the 1<sup>st</sup> above-ground floor of the tract, the central corridor is interrupted by a kitchen. Therefore, access to the canteen and the modified toilet is only through the side entrance of the main building.

## Lift

The lift in the main building (automatically opening door width 90 cm; cabin width 100 cm, depth 140 cm) connects the 2<sup>nd</sup> to 5<sup>th</sup> above-ground floors. The manoeuvring space in front of the lift is sufficient. The cabin is equipped with a handle (height 90 cm) on the sidewall and a mirror (height of the lower edge 5 cm) on the front wall. The controls at the entrances are at a maximum height of 92 cm. The maximum height of the controls inside the cabin is 111 cm.

A lift with opposite doors in the left tract (automatically opening door width 90 cm; cabin width 100 cm, depth 140 cm) connects the 1<sup>st</sup> to 4<sup>th</sup> above-ground floors. The manoeuvring space in front of the lift is sufficient. The cabin is equipped with a handle (height 90 cm) and a mirror (height of the lower edge 93 cm) on the side wall. The controls at the entrances are at a maximum height of 92 cm. The maximum height of the controls inside the cabin is 111 cm.

## Sanitary facilities

A separate accessible toilet (door width 80 cm; stall width 188 cm, depth 300 cm) is located on the ground floor of the left tract near the canteen. The single-panel door to the toilet is marked and opens mechanically outwards. Access to the toilet bowl from the stall entrance is on the left. The space for a wheelchair next to the toilet bowl is sufficient (width 105 cm). The toilet bowl is equipped with two pull-down handles.

# Parking

Reserved parking spaces are not available.